CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7272-0067:223

CATEGORY: Photoelectric Smoke Detector

LISTEE: Siemens Building Technologies/Cerberus Division, 8 Fernwood Rd,
Florham Park, NJ 07932 Contact: Peter Pawchak (973) 593-2662

DESIGN: Models HFP-11 analog and photoelectric type smoke detectors. Model is addressable and communicates with Firefinder-XLS control panel and Model DPU Device Programming Unit. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. Detector intended for installation on a vertical wall surface or the ceiling. Acceptable for duct application with an air velocity of 0-4000 ft/min. when used with Models DB-11 or DB-ADPT bases and Model AD-HR air duct monitoring housing.

MARKING: Listee's name or Cerberus Pyrotronics, model number and UL label.

APPROVAL: Listed as photoelectric type smoke detectors for use with listee's separately listed base Model DB-11, DB-HR or ADBH-11 (CSFM Listing No. 7300-0067:134) and separately listed compatible fire alarm control units.

08-28-2002 JEW

Date Issued: **AUGUST 28, 2002** *Listing Expires* ***June 30, 2003***

Authorized By: ***DIANE K. AREND****, Senior Deputy Program Manager*